



Type Examination Certificate No CH-MI004-13019-04_EN

Translation

Applicant

Sontex SA
Rue de la Gare 27
2605 Sonceboz-Sombeval
Switzerland

Requirements

Ordinance of 15 February 2006 on Measuring Instruments (SR 941.210) and Ordinance of the FDJP of 19 March 2006 on Heat Meters (SR 941.231)

Directive 2004/22/EC of the European Parliament and of the Council of 31 March 2004 on measuring instruments (MID) and the instrument-specific annex MI-004

Conformity standards:
EN 1434: Edition 2007
OIML R75 : Edition 2002

Type of instrument

Compact heat meter

Type designation

Superstatic 749/ Superstatic 789

Accuracy class(es)

2 or 3 (according to the EN1434)

Characteristics


q_p : 0.6 ... 2.5 m³/h
 q_p/q_i : 100
Nominal pressure: 1.6 MPa
Nominal diameter: DN15 to DN20

Certificate valid until

30 July 2023

CH-3003 Bern-Wabern, 26 May 2015

Conformity Evaluation Body METAS-Cert
No 1259



Gulran Couvreur, Head METAS-Cert

Remark: This certificate is a translation. In case of equivocality, the content from the original certificate is decisive